Uniform Plumbing Code Appendix M: Alternative Methodology for Sizing Water Pipes

Opportunity for Early Adoption



Date: December 12, 2022

What is UPC Appendix M?

PROJECT NAME : ick for Drop-down Menu →		6th Avenue Multi-Family Building		Total Number of Apartments in the Building→ 24 Total Apartments in this Calculation→ 24			 Tuesday, July 27, 2021 6:24 PM
FIXTURE GROUPS		FIXTURE	ENTER TOTAL NUMBER OF FIXTURES	PROBABILITY OF USE (%)	ENTER FIXTURE FLOW RATE (GPM)	MAXIMUM RECOMMENDED FIXTURE FLOW RATE (GPM)	COMPUTED RESULTS FOR PEAK PERIOD CONDITIONS
Bathroom Fixtures	1	Bathtub (no Shower)	0	0.54	5.5	5.5	
	2	Bidet	0	0.60	2.0	2.0	Total No. of Fixtures in Calculat
	3	Combination Bath/Shower	24	2.08	5.5	5.5	n = 74
	4	Faucet, Lavatory	24	1.37	1.5	1.5	
	5	Shower, per head (no Bathtub)	0	1.42	2.0	2.0	99 th Percentile Demand Flow
	6	Water Closet, 1.28 GPF Gravity Tank	0	0.60	3.0	3.0	Q = 17.5 GPM
Kitchen Fixtures	7	Dishwasher	0	0.36	1.3	1.3	
	8	Faucet, Kitchen Sink	24	1.37	2.2	2.2	Hunter Number
Laundry Room Fixtures	9	Clothes Washer	2	2.01	3.5	3.5	H(n,p)=1.20
	10	Faucet, Laundry		1.37	2.0	2.0	
Bar/Prep Fixtures	11	Faucet, Bar Sink	0	1.37	1.5	1.5	Stagnation Probability
Other Fixtures	12	Fixture 1	0	0.00	0.0	6.0	Pr[Zero Demand] = 30%
	13	Fixture 2	0	0.00	0.0	6.0	
	14	Fixture 3	0	0.00	0.0	6.0	

An alternative method for estimating the demand load for the building water supply, principal branches, and risers for single- and multifamily dwellings

2021 UPC, Appendix M "Peak Water Demand Calculator" http://epubs.iapmo.org/2021/UPC/#p=453 and https://www.iapmo.org/water-demand-calculator

2017 Study on Peak Water Demand by S. Buchberger et al. (basis for Water Demand Calculator) https://www.iapmo.org/media/3857/peak-water-demand-study-executive-summary.pdf

Benefits of Using UPC Appendix M


- Water and embedded energy savings due to faster hot water delivery times
- Additional energy savings due to decreased heat loss in the hot water distribution system, particularly in multifamily buildings with a recirculation system
- Reduced public health and safety risk and improved water quality due to shorter water dwell times in plumbing systems
- Construction cost savings due to smaller diameter pipes and fittings, less pipe insulation material, and reduced water service entrance size

2020 Study on Water Demand Calculator by Stantec (assessment of cost savings from using Water Demand Calculator) <u>https://www.iapmo.org/group/update/stantec-wdc-savings-study</u> 2021 Bapart on Connection Face and Service Charges by Mater Size by Alliance for Water Efficiency (assessment of cost saving


2021 Report on Connection Fees and Service Charges by Meter Size by Alliance for Water Efficiency (assessment of cost savings from downsizing meters) https://www.iapmo.org/media/25939/awe-meter-size-connection-fee-research.pdf

Standard Practice Overestimates Peak Flow Rates

Comparing Hunter's Curve to Actual Peak Flow Rates Hunter's Curve (1940) is the basis of Uniform Plumbing Code Appendix A



The Original Hunter Papers: The Foundation of Plumbing Engineering https://www.aspe.org/product/the-original-hunter-papers-the-foundation-of-plumbing-engineering 2021 UPC, Appendix A "Recommended Rules for Sizing the Water Supply System" https://epubs.iapmo.org/2021/UPC/#p=326




Analyzed actual hot flow rates from 20 **multifamily buildings** ranging from 8 to 384 apartments

UPC Appendix A (standard practice) design values are 5 to 27 times larger than the observed peak hot water flow rates

Many thanks to Association for Energy Affordability, Ecotope, Frontier Energy, Peter Skinner, and UC Davis Western Cooling Efficiency Center for providing data.

Comparing Design Predictions to Actual Peak Flow Rates Peak Hot Water Flow Rates in Multifamily Buildings



Monitoring period ranged from 9 days to over 2 years and logging interval ranged from 1 to 60 seconds depending on the building. Out of order letters are for four buildings that were added after the submittal of the original 11/3/2021 petition to California state agencies. **UPC Appendix M** design values are between 2 and 6 times the observed peak hot water flow rates in 20 multifamily buildings

Many thanks to Association for Energy Affordability, Ecotope, Frontier Energy, Peter Skinner, and UC Davis Western Cooling Efficiency Center for providing data.

Who Has Adopted UPC Appendix M Already?

Uniform Plumbing Code 2018 of Nevada

ADOPTS WITH AMENDMENTS: UPC 2018



2018 North Dakota Plumbing Code ADOPTS WITH AMENDMENTS: UPC 2018

sanjoseca.gov

Uniform Plumbing Code 2018 of Hawaii ADOPTS WITH AMENDMENTS: UPC 2018

Foster City Municipal Code

TITLE 14HOUSING AND CONSTRUCTIONCHAPTER 8PLUMBING CODESPART 22021 NEW MEXICO PLUMBING CODE



Thank You

Contact Information

Gary Klein Gary@GaryKleinAssociates.com (916) 549 7080

Steffi Becking <u>steffibecking@2050partners.com</u> (650) 804 6155

